

**WALLPIPE MIN DIMENSIONS**

Overall Length

last edit 2/28/2006

SIZE	MJxMJ	MJxFLG	MJxPE	FLGxFLG	FLGxPE	PExPE
3"	10"	8"	8"	5"	3"	1"
4"	10"	8"	8"	5"	3"	1"
6"	10"	8"	8"	6"	3"	1"
8"	10"	8"	8"	6"	3"	1"
10"	1'-0"	10"	8"	7"	4"	1"
12"	1'-0"	10"	8"	7"	4"	1"
14"	1'-3"	10"	8"	7"	4"	1"
16"	1'-3"	10"	8"	7 1/2"	4"	1"
18"	1'-4"	1'-0"	8"	8"	4"	1"
20"	1'-4"	1'-0"	8"	8"	4"	1"
24"	1'-4"	1'-0"	8"	9"	4 1/2"	1"
30"	1'-8"	1'-4"	1'-3"	11"	5"	1"
36"	1'-9"	1'-5"	1'-4"	1'-0"	5 1/2"	1"

Note: 30" collars 9 1/2" and 36" collars 10" from bell

**FABRICATED PIPE MIN DIMENSIONS**

ALL else is laying length

SIZE	FLG x FLG
3"	4"
4"	4"
6"	4 1/2"
8"	5"
10"	5 1/2"
12"	6"
14"	6"
16"	6 1/2"
18"	7"
20"	7 1/2"
24"	8 1/2"
30"	9 1/2"
36"	11"

single point thd.	Required	extra\$
-------------------	----------	---------

"	"	"
"	"	"
"	"	"
"	"	"
"	"	"

Wallpipe is measured "Overall" unless told otherwise